This is GE-Lynn

**GE** Aviation

2013





GE Proprietary Information — The information contained in this document is GE proprietary information and is disclosed in confidence. The property of GE and shall not be used, disclosed to others or reproduced without the express written consent of GE, including, but without limitance is not to be used in the creation, manufacture, development, or derivation of any repairs, modifications, spare parts, designs, or configuration changes or to obtain FAA or any other government or regulatory approval to do so. If consent is given for reproduction in whole or in part, this notice and the notice set forth on each page of this document shall appear in any such reproduction in whole or in part. The information contained in this document may also be controlled by the U.S. export control laws. Unauthorized export or re-export is prohibited.

# Engineering and Mathematics Practical Applications

GE Aviation Lynn, MA
Facilities Engineering
and
Edmund (Ted) Tarallo
Salem High School



## **GE Lynn Facility**

#### 225 acres • 20 buildings




#### **Prominent Role**

- > Largest Aviation manufacturing site
- > Represents 2/3<sup>rd</sup> of MSO sales
- > GE38, 701K, HF120 Development
- Key Product & Technology Engineering
- Largest GE Massachusetts business

#### Facility Highlights

- > Mechanical Integrity Program
- Plant Electrical Updates






## What We Do....





We invent the future of flight, We lift people up & bring them home safely

#### Design



#### **Manufacture**



**Assembly/Test** 




**Facility Engineering** 





GE Proprietary Information
Use or disclosure of data contained on this sheet is subject to the restrictions on the cover or first

## Building 74 3rd HVAC Project





## Pressure Rating of Pipe

Pipe Burs	t Pressue/	Min Wall Thickness	(Barlow's	Formula)						
Solvina f	or Pressure	_			Solving fo	r Thickne	cc	-		
P =	#DIV/0	Max. Working Pressure	(nsi)		P =			king Pressur	re (psi)	
E =		Longitudinal Joint Eff. Fa			E =			nal Joint Eff. F		
s =		Material Strength(Allowa	ble Stress	(psi)	s =	30000			wable Stress)	) (psi)
t =		Wall Thickness (in)			t =	0.085		Thickness (in		
do =		Outside Diameter (in)			do =	6.065		iameter (in)		
SF =		Safety Factor (1.5 - 10)			SF =	2		ctor (1.5 - 10		
A =		Allowance for Corrosion			A =	0.065	Allowance	for Corrosion	n	
D 01-151	. A\//-I- *	OE/			//D*-I-*	05\/ (0 * 0	+ F\\ . A		E	1000
P=2"S"E"(	t -A)/ (do *	SF)			t = ((P*do*)	SF)/ (2 " S	" E)) + A			No.
Closed Sv	stems A =	0.025 in		ACID	orbital Committee of the Committee of th	No. of Street, or other transferred	100000			
	tems $A = 0$			4		1				
				- Marie		1	-	700	(9)	
				White B		100		L-1		
	eel Seamle			73		1	1570			
A53 Grade		(1/4" - 26")				200			and the	Mary Control
Yield	35 ksi			34 34 44		8 3 A	200	7		
E	1			Control of the Contro		+ diction	100			del
A 400 O	l- D	(4/4   00  )				10.00	4.5			A
A106 Grad Yield	ie B 35 ksi	(1/4" - 30")		W. W. 1979		100	THE REAL PROPERTY.	190	3.3	100
E	35 KSI					16/164	3 964	A SECOND		30
_	1			10000			S 32 1 A			
Stainless	Steel			Sales of	- CO					
		P316 (1/4" - 30")		100		The same of	4	19		
Yield	30 ksi									
E	0.85			Charles an walking high	MARKET MARKET TO STATE AT		EXPERIENCE - 10.00	039 E		



### **Corrosion Calculations**





Corrosion Rate (ST) =  $t_{previous} - t_{actual} / (time between t_{previous} and t_{actual} (Years))$ 

Remaining Life =  $t_{actual}$  -  $t_{required}$  / corrision rate

 $t_{\text{initial}}$  = the initial thickness at the same CML (Corrosion Monitoring Location) as  $t_{\text{actual}}$ .



## Pressure Drop Calculations


Note:		PIPE RUN		A-B		
	D	Selected Pipe Diameter (ft)			0.51	
	d	Selected Pipe Diameter (in)			6.07	
		Pipe Area (ft <sup>2</sup> )			0.201	
	V	Velocity in Pipe(ft/sec)			332.2194	
	q	Total flow rate (ft <sup>3</sup> /min)			4000	
	q	Total flow rate (ppm)			323	
	q	Total flow rate (pps)			5.4	
	Re	Reynolds Number			1.087E+05	
	ε/D	Pipe Roughness			2.967E-04	
		Pipe Run Length (no Fittings)(ft)			100	
		Fittings - Equivalent length for Pipe		QTY	TTL Eq L	
		Entry loss	48		0	
		12" 90 degree ell	30		0	
		12" 90 degree long ell	19		0	
		12" 45 degree ell	16		0	
		4" 90 degree ell	10	3	30	
		4" 90 degree long ell	6.7		0	
		4" 45 degree ell	5.2		0	
		3" 90 degree ell	7.5		0	
		3" 90 degree long ell	5		0	
		3" 45 degree ell	4		0	
		12" Gate Valve	13		0	
		4" Gate Valve	4.5		0	
		3" Gate Valve	3.2		0	
		12" Tee through run	20		0	
		4" Tee through run	6.7		0	
		3" Tee Through run	4		0	
		Exit loss	64		0	
		12" Check Valve	120		0	
		4" Check Valve	40		0	
		4" 3-Way Valve	20	1	20	
		Dresser coupling			0	
		4" Y fitting 45 degree	6		0	
		12" Y fitting 45 degree	18		0	
		Sudden Contraction			0	
		Sudden Enlargement			0	
		12" Strainer	180		0	
		4" Strainer (4.5 psi)			0	
		Gen. Heat Exchanger (8 psi)			0	
		Blow out line with Strainer	35		0	
		Total Friction Loss Fittings			50	
	ρ	Density (lbm/ft <sup>3</sup> )			0.517	
		Temp in Pipe Run (°F)			140	
	f	Friction Factor			0.016	
	Leq	Total Equivalent Length			150	
	ΔP	Total Pressure Drop (psi)			35.36	
	h <sub>I</sub>	Total Head (ft)			79.82	

Bernoulli Equation – The total energy possessed by the fluid is the sum of its pressure, kinetic, and potential energies


$$Et = Ep + Ev + Ez$$

Et = 
$$p/\rho + v^2/2 + zg$$
 (SI)

$$Et = p/\rho + v^2/2*gc + zg/gc (US)$$



$$(Ep + Ev + Ez)_1 + E_A = (Ep + Ev + Ez)_2 + E_E + E_f + E_m$$







## Pressure Relief Valve Calculations











Compressed	Air Relief \	√alve Solving for Flow					
SCFM = A *	6.32* C * K	* P * KB / SQRT(T * G * Z)					
SCFM =	24833.1						
PPM =	2004.031						
PPS =	33.40052						
A =	12.56	SQ IN					
SCFM =		Flow					
T =	520	Abs Temperature Deg R (R=F+460)					
M =	29.0	Molecular Weight					
Z =	1	Compressibility Factor					
C =	315	Coefficient determined from expression of ratio of specific heats (C=315 if value is not known)					
K =	0.975	Effective Coefficient of Discharge					
P =	125	Relieving Pressure (psia) (P=Set Pressure (psig) + Over Pressure (+10%) + atmospheric pressure (14.7 psia))					
K <sub>B</sub> =	1	Capacity correction factor due to back pressure (K <sub>B</sub> =1.0 for atmospheric discharge)					



#### Pressure Relief Device Inspection Checklist

#### **QUALITY AND COMPLIANCE:**

Verified By

## FACILITY ENGINEERING DATA MANAGEMENT PLAN



Maximo


**Inspection Checklist** 

Manufacturer Information

Calculations supporting the Design

Inspection
Data/Certifications







Follow - On Corrective Maintenance Records Applicable

**GE Proprietary Information** 

Overpressure Protection Device Field Verification Data

Use or disclosure of data contained on this sheet is subject to the restrictions on the cover or first page.

## **QUESTIONS**



